

START OF PIPE

15:24 ↖

4G 

Upgrade



Latitude

56.193827

Longitude

-2.881243

Accuracy: 5 m

Last location age: 0 seconds



END of Pipe'

08:45 ↗

4G 

Upgrade



Latitude

---

56.194283

---

Longitude

---

-2.883122

---

Accuracy: 5 m

---

Last location age: 0 seconds

---



PUBLIC REGISTER COPY

WPC/E/2094

No. 609  
(Revised)

FORTH RIVER PURIFICATION BOARD

CAR/L/1001486

County Offices,  
Viewforth,  
Stirling.

11th March, 1971.

Thomson Caravans Limited,  
Per Messrs. Johnston and South,  
Barony House,  
Cupar.

Dear Sir(s)/~~Madam~~

Rivers (Prevention of Pollution) (Scotland) Acts, 1951 and 1965.

Your application for consent to the <sup>now</sup> discharge of sewage effluent  
from a caravan site at Shell Bay, Elie  
into the Forth Estuary  
in the County of Fife

has been considered and is approved for the purposes of the Rivers (Prevention of  
Pollution) (Scotland) Acts, 1951 and 1965, subject to the conditions contained in the  
Appendix hereto.

The reasons for the imposition of the said conditions are as follows:-

to preserve the amenity of the foreshore of the Forth Estuary.

Attention is directed to the provisions of Section 5(1) of the Rivers (Prevention  
of Pollution) (Scotland) Act, 1965, which require a River Purification Authority from  
time to time to review any conditions imposed.

The terms of this consent will not, without the consent in writing of the person  
to whom this consent is given (or his successor), be altered before the expiration of the  
period ending with the Tenth day of March 19 76.

Attention is also directed to the provisions of Section 23(10) of the 1951 Act  
and Section 6(1) of the 1965 Act which provide that if an applicant is aggrieved by the  
refusal of a River Purification Authority to consent to an application or by the terms of  
any such consent, he may within three months of his receipt of the decision on his  
application appeal in writing to the Secretary of State.

I am,  
Yours faithfully,

Clerk to the Board.

APPENDIX /

APPENDIX.

1. The discharge shall be by the outlet(s) at the point(s) indicated on the site plan or map docketed and signed with reference to ~~the following Consent No. 609~~ Consent No. 609
2. The discharge ~~in any weather~~ shall not exceed 110,000 gallons per day at a maximum rate of discharge of 21,000 gallons per hour.
3. The temperature of the discharge shall not exceed 30°C.
4. The discharge shall not contain more than 120 parts per million of suspended solids.
5. The outlet shall be by a 9" cast iron pipe.