

Tuesday, 05 January 2021

MS.MarineRenewables@gov.scot



Development Operations
The Bridge
Buchanan Gate Business Park
Cumbernauld Road
Steps
Glasgow
G33 6FB

Development Operations
Freephone Number - 0800 3890379
E-Mail - DevelopmentOperations@scottishwater.co.uk
www.scottishwater.co.uk

Dear Sir/Madam

SITE: Stornoway Deep Water Port, Glumaig Bay, Stornoway
PLANNING REF: 00008749/ 00008748
OUR REF: DSCAS-0029619-9K4
PROPOSAL: Stornoway Harbour Authority - Construction and Capital Dredging - Deep Water Port, Glumaig Bay, Stornoway

Please quote our reference in all future correspondence

[Audit of Proposal](#)

Scottish Water has no objection to this planning application; however, the applicant should be aware that this does not confirm that the proposed development can currently be serviced and would advise the following:

[Asset Impact Assessment](#)

According to our records, the development proposals impact on existing Scottish Water assets.

The applicant must identify any potential conflicts with Scottish Water assets and contact our Asset Impact Team via [our Customer Portal](#) to apply for a diversion.

The applicant should be aware that any conflict with assets identified may be subject to restrictions on proximity of construction. Please note the disclaimer at the end of this response.



To find out more about connecting your
General property to the water and waste water supply visit:



So, how are we doing?

We'd love to know what we're
doing well or could do better.
We promise we're listening,
[click here](#) to tell us...



Drinking Water Protected Areas

A review of our records indicates that there are no Scottish Water drinking water catchments or water abstraction sources, which are designated as Drinking Water Protected Areas under the Water Framework Directive, in the area that may be affected by the proposed activity.

Surface Water

For reasons of sustainability and to protect our customers from potential future sewer flooding, Scottish Water will not accept any surface water connections into our combined sewer system.

There may be limited exceptional circumstances where we would allow such a connection for brownfield sites only, however this will require significant justification from the customer taking account of various factors including legal, physical, and technical challenges.

In order to avoid costs and delays where a surface water discharge to our combined sewer system is anticipated, the developer should contact Scottish Water at the earliest opportunity with strong evidence to support the intended drainage plan prior to making a connection request. We will assess this evidence in a robust manner and provide a decision that reflects the best option from environmental and customer perspectives.

General notes:

- ▶ Scottish Water asset plans can be obtained from our appointed asset plan providers:
 - ▶ Site Investigation Services (UK) Ltd
 - ▶ Tel: 0333 123 1223
 - ▶ Email: sw@sisplan.co.uk
 - ▶ www.sisplan.co.uk

I trust the above is acceptable however if you require any further information regarding this matter please contact me on **0800 389 0379** or via the e-mail address below or at planningconsultations@scottishwater.co.uk.

Yours sincerely,

Planning Application Team

Development Operations Analyst

developmentoperations@scottishwater.co.uk



SW Public
General

To find out more about connecting your property to the water and waste water supply visit:



So, how are we doing?

We'd love to know what we're doing well or could do better. We promise we're listening, [click here](#) to tell us...



Scottish Water Disclaimer:

"It is important to note that the information on any such plan provided on Scottish Water's infrastructure, is for indicative purposes only and its accuracy cannot be relied upon. When the exact location and the nature of the infrastructure on the plan is a material requirement then you should undertake an appropriate site investigation to confirm its actual position in the ground and to determine if it is suitable for its intended purpose. By using the plan you agree that Scottish Water will not be liable for any loss, damage or costs caused by relying upon it or from carrying out any such site investigation."



To find out more about connecting your
SW Public
General property to the water and waste water supply visit:



So, how are we doing?
We'd love to know what we're doing well or could do better. We promise we're listening, [click here](#) to tell us...